




- CHECKOUT INSTALLATION NOTES**
- SEE SHEET E4.03 FOR WORKROOM, CUSTOMER SERVICE AND CHECKOUT COMMUNICATION WIRING.
  - MOUNT QUAD OUTLET FLUSH IN THE CHECKOUT STAND FOR THE VISU COOLER(S) AND LED CANDY RACK LIGHTING AT THIS LOCATION. RECEPTACLE TO BE MOUNTED 1'-4" A.F.F. IN THE SIDE NEAREST THE CASHIER AND ACCESSIBLE TO THE VISU COOLER CONNECTION. FACE PLATE TO BE PAINTED TO MATCH CHECKOUT STAND COLOR. COORDINATE LOCATION WITH PRE-WIRED CONTROLS MOUNTED INSIDE THE CHECKOUT.
  - CASH REGISTER CIRCUITS SHALL BE PROVIDED WITH DEDICATED NEUTRAL AND GREEN ISOLATED GROUND.
  - EX CABLES SHALL BE INSTALLED WITH INSULATED THROATS AND APPROVED CONNECTORS.
  - ELECTRICAL CONTRACTOR & FOOD LION COMMUNICATION VENDOR SHALL COORDINATE TELEPOLE LOCATIONS WITH LIGHTING & HVAC PRIOR TO INSTALLATION TO MINIMIZE INSTALLATION CONFLICTS.


ALL POWER OUTLETS AND JUNCTION BOXES BEHIND NEW CABINET SHALL BE RELOCATED UP TO 48" AFF (ELECTRICAL CONTRACTOR SHALL ADD A RECEPTACLE AT 48" AFF IF ONE NOT ALREADY PRESENT). FIELD VERIFY EXACT AMOUNT OF WORK REQUIRED, COORDINATE WITH DELHAIZE CONSTRUCTION SUPERVISOR.




**4 ASSOCIATE SIDE ELECTRICAL ELEVATION**  
SCALE : NONE  
E4.02



**WIRING HARNESS (SUPPLIED WITH CHECKOUT)**




**1 ENLARGED ELECTRICAL POWER PLAN**  
SCALE : 3/16" = 1'-0"  
E4.02




- 2 CHANNEL TELEPOLE (TYPE C)
- 1 DIRTY CIRCUIT
- 2 CLEAN CIRCUITS (1 PER S.C.O.)
- 4 CAT-5e CABLES (2 PER S.C.O. FOR REGISTER & CATALINA)

**6 SELF CHECKOUT POWER POLE DETAIL**  
SCALE : NONE  
E4.02



**5 CUSTOMER SERVICE KIOSK ELECTRICAL ELEVATION**  
SCALE : NONE  
E4.02



**2 CUSTOMER SERVICE KIOSK ELECTRICAL PLAN**  
SCALE : 1/2" = 1'-0"  
E4.02

- ELECTRICAL WIRING KEY NOTES**
- EXISTING PANEL SCHEDULE FOR PANEL OW, CR NOT LABELED CORRECTLY. ELECTRICAL CONTRACTOR TO TRACE AND FIELD VERIFY EACH CIRCUIT IN PANEL OW AND PROPERLY LABEL CIRCUITS IN TYPED WRITTEN PANEL SCHEDULE IN PANEL.
  - ELECTRICAL CONTRACTOR TO CONNECT POWER FOR NEW CHECK STAND "DIRTY POWER" AND VISU COOLERS TO EXISTING CIRCUITS IN PANEL OW MADE SPARE BY REMOVAL OF EXISTING CHECK STAND EQUIPMENT.
  - ELECTRICAL CONTRACTOR TO RECONNECT RELOCATED EQUIPMENT TO EXISTING CIRCUITS AT NEW LOCATION. EXTEND EXISTING CIRCUITRY AS REQUIRED.
  - VERIFY EXISTING CONDITIONS- CIRCUIT TO BE DEDICATED FED FROM CR PANEL, CIRCUIT AS NECESSARY.
  - ELECTRICAL CONTRACTOR TO CONNECT NEW EQUIPMENT TO NEW CIRCUITS OR REUSE EXISTING CIRCUITS AS REQUIRED.
  - CONDUITS ON THIS WALL TO BE RECESSED BEHIND GWB.
  - DEDICATED 120V RECEPTACLES FOR NEXGEN DATA CABINET PROVIDED AND INSTALLED ABOVE CEILING BY SEPARATE OWNER CONTRACTOR.
  - 3' 2 DOOR VISU COOLER, 120V, 3.3 AMPS, 9" CORD W/ NEMA 5-15 PLUG.
  - FRONT-END SET TEAM (FOOD LION VENDOR) SHALL PROVIDE POWER AND PULL (2) CAT-5 UNSHELD EHTERNET CABLES PER REGISTER (REGISTER, CPU, & CATALINA PRINTER) SEE A1.01. COIL 15'-0" OF EXTRA CABLE AT EACH END FOR CONNECTION BY OTHERS (MACRO).
  - ROUTE PARTIAL HEIGHT WALL CIRCUITS THROUGH POWER POLE TO ABOVE CEILING.